


Product Specification

SKU#	Description:	6 Outlet Power Strip	
Photo(s)		Color	Indent Marking based on cULus or equivalent standard
		Grey	(ETL)us ETL#____SJT 3X14AWG 60°C 300V VW-1 c(ETL) SJT 3X2.08mm2 (14AWG) FT2
		Raw Material	
		Plastic: ABS 90g	
Key Features & Specs		Copper Strip: 7.8g	Compound Requirement
Male Blades:UL CUL Recognized Components(NEMA-5-15P) Female Contacts:UL CUL Recognized Components(NEMA-5-15P) Female Ground:UL CUL Recognized Components(NEMA-5-15P) Label:UL CUL required Agency Approvals:ETL Listing Rate: AC 15A 125V 60Hz 1875W		Cabel: 3C SJT 14AWG 0.66FT	PVC 60°C Insulation Compound Approved for SJT Cable
		Jacket Construction	Cold Bend Test Requirement
		100% Fully Pressure Extruded Jacket	Must pass cold bend test at -20°C
Test			
Hipot test @1.5KV Power test @ with light can light Drop test @70cm Grounded test@ with ground equirement			
ETL file #	UL file #	CSA/UL file #	
	E308551		Date: 2011.11.15